

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2023/ School/ 650

Dated: 20/09/2023

FIRE SAFETY CERTIFICATE

Certified that the Anglo Arabic Sr. Sec. School located at Ajmeri Gate, Delhi is comprised of 03 block (ground floor only) & 03 block (Ground + 01 Upper floor, but school running at ground floor only), was inspected by the officer concerned of this department on 13-09-2023 in the presence of Mr. Abdul Kadir and found that school building ground floor has complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises (ground floor) is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from.....20/09.....2023 for a period of three years subject to compliance of the conditions mentioned below:

Issued on20/09/2023..... at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Principal, Anglo Arabic Sr. Sec. School at Ajmeri Gate, Delhi.
3. Director of Education, NDMC, Dr. SPM Civic Centre, JLN Marg, Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration shall strictly prohibited.



MOJIB WASIM AHMAD
PRINCIPAL
ANGLO ARABIC SR. SEC. SCHOOL
AJMERI GATE, DELHI-110006
Phone : 23212724

