



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
OFFICE OF THE DEPUTY HEALTH OFFICER
CITY-SP ZONE, KASHMERE GATE DELHI-06
Email ID: - dhocityzone@gmail.com

75
आज़ादी का
अमृत महोत्सव

No. DHO/CSPZ/2023/D-1153

Date:- 29-9-2023

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Munish Meena (APHI) from Public Health Department, City SP Zone inspected the **Anglo Arabic Senior Secondary School** situated at **Ajmeri Gate, Delhi 110006** and found that Anglo Arabic Senior Secondary School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for one year from date of issue.

Handwritten: 28/9/23
Dy. Health Officer
City SP Zone
Dr. Hemant Kumar
Deputy Health Officer
Municipal Corporation of Delhi
C.S.P. Zone
Copy to:

- School Principal
Anglo Arabic Senior Secondary School
Ajmeri Gate Delhi 110006
- O/c


Handwritten signature
APHI/CSPZ
Munish Kumar Meena
APHI/CSPZ/MCD

Handwritten signature
MOHD. WASIM AHMAD
PRINCIPAL
ANGLO ARABIC SR. SEC. SCHOOL
AJMERI GATE, DELHI-110006
Phone : 23212734





DELHI JAL BOARD: GNCTD
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54



TEST REPORT

Sample ID	Ref.No. D.J.B/CWA/Wzd./2023-24/paid-262-263		
Location /Address of Sample	Anglo Arabic Senior Secondary School, Ajmer Gate, Delhi-110006		
Reference No.	AASSS/2024	Ref. Letter Date	20.03.2024
Challan No.	478	Challan Date	21.03.2024
Sample collection date	22.03.2024	Analysis start date	22.03.2024
Any other Information	--	Analysis end date	24.03.2024
		Reporting date	28.03.2024

TEST RESULTS

S. No.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Colour	CU	5	15	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	2.7	1.5
4	pH Value	--	6.5-8.5	No relaxation	7.89	7.81
5	Electrical Conductivity	µS/cm	-	-	398	407
6	Total Dissolved Solids	mg/L	500	2000	259	265
7	Total Alkalinity	mg/L	200	600	100	104
8	Total Hardness	mg/L	200	600	158	164
9	Calcium as Ca	mg/L	75	200	43	44
10	Magnesium as Mg	mg/L	30	100	12	13
11	Iron	mg/L	1.0	No relaxation	0.08	0.10
12	Chloride	mg/L	250	1000	40	42
13	Fluoride	mg/L	1.0	1.5	0.59	0.63
14	Ammonical-Nitrogen	mg/L	NIL	0.5	BDL	BDL
15	Nitrate	mg/L	45	No relaxation	5.9	6.5
16	Sulphate	mg/L	200	400	25.8	26.3
17	Residual Chlorine	mg/L	0.2	1.0	0.50	0.20
18	Coliform Count at 37° (MPN)	100 mL	Absent	--	0	0

*BDL=Below Detection Limit

.....End of Report.....

Remarks: For the tested parameters water samples conform drinking Water Specification IS-10500 & can be considered fit for drinking purpose.

Tested by
Lab.Tech.

Verified by
Asstt. Chemist

Authorized by
Chemist

ACWA(WZD)

MOHD. WASIM AHMAD
PRINCIPAL
ANGLO ARABIC SR. SEC. SCHOOL
AJMERI GATE, DELHI-110006
Phone : 23212724

